



Titeflex Corporation  
1116 Vaughn Parkway  
Portland, TN. 37148  
Tel. 833-798-4661  
[www.pythonls.com](http://www.pythonls.com)

## Technical Bulletin TBPL2023-01

### Enclosed Python Fittings

March 28, 2023

In regard to enclosing Python fittings and couplers, please reference and follow the below section of IMC.

**IMC Section 1110.2 Exposure of refrigerant piping system: Refrigerant pipe and joints installed in the field shall be exposed for visual inspection and testing prior to being covered or enclosed.**

This means that you can enclose fittings and couplers within the piping system as long as these connection points have been visually pressure tested for leaks before enclosing.

