



Titeflex Corporation
1116 Vaughn Parkway
Portland, TN. 37148
Tel. 833-798-4661
www.pythonls.com

Technical Bulletin TBPL2023-02

Horizontal Support Spacing and Hangers

March 28, 2023

The UMC Code states the following for refrigeration pipe supports:

UMC 1109.6 Support:

In addition to the requirements of Section 1105.2, piping and tubing shall be securely fastened to a permanent support within 6 feet following the first bend in such tubing from the compressor and within 2 feet of each subsequent bend or angle. Piping and tubing shall be supported at points not more than 15 feet apart.

Hanger:

A proper support is one that is designed as a pipe hanger, does not damage the line set during installation and provides full support.

